




TEST CERTIFICATE

SUMMARY OF TEST RESULTS

| | | | |
|-----------------------------|---|-------------|--------------------|
| NUMBER | 0407 | DATE | 18 /02 / 04 |
| Client' s data: | ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 190 18 MAGOULA ATTIKIS GREECE | | |
| Product description: | SINGLE SASH WINDOW OPENING / TILTING | | |
| Material: | ALUMINIUM | | |
| System : | E - 1000 | | |



1360 x 1360 mm

| | |
|--|-----------------|
| Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i> | Class 4 |
| Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i> | Class 8A |
| Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | Class C4 |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

MARIANTHI CHATZIANTONIOU
TECHNICAL MANAGER

IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL