


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 08162 / 05.01.2009**

NUMBER	08162	DATE	05 / 01 / 2009
---------------	--------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIUO STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH WINDOW WITH FIXED GLAZING TILT / TURN
Material:	ALUMINIUM
System :	E - 45



1400 x 2200 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E750
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.


SINOPI PAPAPOPOULOU
TECHNICAL MANAGER


IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL